


Duke Energy Resource Adequacy Philosophy and Methods

Benjamin Borsch
Director, Integrated Resource Planning & Analytics
Duke Energy Florida

Energy Systems Integration Group
2019 Fall Technical Workshop
October 28, 2019

Integrated Utilities have a mission to provide:
Reliable, Affordable, Increasingly Clean Power
in a safe and environmentally compliant manner.

- Resource adequacy refers to the ability of the electric system to supply the aggregate electrical demand and energy requirements of customers at all times.



Balance of Sources

◆ Owned Generation ◆ QF ◆ DSM ◆ Other Purchases

Conventional
Generation and
Purchases



Renewables



Solar, Wind,
Biomass,
MSW

Energy Efficiency and
Load Control



Characteristics

◆ Fuel Type and Supply ◆ Unit Performance ◆ Reliability / System Support

- Adequacy requires Reserves.
- Reserve capacity must be available to account for
 - Capacity Variation
 - Load Variation
- A reserve margin target is utilized in the IRP process to ensure resource adequacy
 - The Reserve Margin is based on annual or seasonal peak load.
- The reserve margin target is established based on probabilistic analyses

Metrics

- Loss of Load Expectation (LOLE)
- Industry utilized 1 day in 10 years standard = 0.1 LOLE

Objective:

- Meet the reliability standard at the lowest total system cost

Implication:

- High Impact Low Probability Analysis
- Requires a large number of scenarios
- 95% of all reliability events will occur in <10% of all scenarios simulated


- Weather Uncertainty: 36 Weather Years Modeled
- Load Growth Uncertainty: 5 Economic Growth Multipliers
- Unit Performance Uncertainty: Monte Carlo Draws for Unit Outages, 20 Draws
- Total iterations at each reserve margin scenario
 - $36 \text{ weather years} \times 5 \text{ load forecast error multipliers} \times 20 \text{ unit outage draws} = 3,600 \text{ iterations}$



Physical Reliability Metric Results

Winter Reserve Margin	13.0%	14.0%	15.0%	16.0%	16.5%	17.0%	18.0%
January	0.104	0.090	0.077	0.066	0.061	0.056	0.047
February	0.020	0.016	0.013	0.009	0.008	0.007	0.005
March	0.018	0.016	0.013	0.011	0.010	0.009	0.007
April	0.000	0.000	0.000	0.000	0.000	0.000	0.000
May	0.000	0.000	0.000	0.000	0.000	0.000	0.000
June	0.000	0.000	0.000	0.000	0.000	0.000	0.000
July	0.028	0.020	0.015	0.012	0.011	0.011	0.009
August	0.028	0.020	0.014	0.010	0.009	0.008	0.006
September	0.000	0.000	0.000	0.000	0.000	0.000	0.000
October	0.000	0.000	0.000	0.000	0.000	0.000	0.000
November	0.000	0.000	0.000	0.000	0.000	0.000	0.000
December	0.005	0.004	0.003	0.002	0.001	0.001	0.001
Summer LOLE	0.056	0.040	0.029	0.023	0.020	0.018	0.015
Winter LOLE	0.148	0.126	0.106	0.088	0.080	0.072	0.059
Total LOLE	0.204	0.166	0.135	0.111	0.100	0.091	0.075


Net Load Variability Increases With PV Penetration Rate



The normalized standard deviation of ramps is the ratio between net load and load without PV




Total System Energy Costs by Reserve Margin




Includes EUE Cost

- vs.
- Production costs
 - Cost of available power for purchase/import
 - Societal cost of Unserved Energy
 - Marginal Cost of New Resources




Example Load Duration Curve and Generation Stack






Summer Load Shape – Solar Effect



— Gross Load 3-Oct — Net Load 3-Oct

	HE14	HE15	HE16	HE17	HE18	HE19	HE20	HE21	HE22	HE23	HE24
Gross Load	11,607	11,890	12,040	12,047	11,934	11,932	11,801	11,281	10,413	9,471	8,568
Solar Output	1,831	1,773	1,596	1,266	769	278	61	30	28	28	27
Net Load	9,776	10,117	10,444	10,781	11,165	11,654	11,740	11,251	10,385	9,443	8,541

Example Load and Solar Generation - January 2018





Aging
Fleet ...



PARIS2015
UN CLIMATE CHANGE CONFERENCE
COP21·CMP11



United Nations
Framework Convention on
Climate Change



