

Maintaining operational demand in South Australia (400 MW): 14 March 2021 event

21 March 2022



Agenda

- Overview of the National Electricity Market – South Australia region
- Case study: South Australia low demand system incident, 14 March 2021
- Improvement actions and recommendations
- Questions


National Electricity Market

- Longest interconnected power system (5,000 km)
- 40,000 km of transmission
- 10 million customers
- Peak load: 36 GW
- Minimum load: 14 GW
- 59 GW of generation capacity
- 14 GW rooftop solar (25% of capacity)




South Australia region

- Synchronous generators
- High renewable penetration
 - 416 MW grid solar
 - 2.05 GW grid wind
 - 1.8 GW of distributed PV
 - Growing at ~20 MW p/month
- 1 x HVDC interconnector
- 2 x 275 kV AC circuits






AEMO Insights: South Australia



SA's average generation by fuel source in 2021




In 2021, renewable energy generation met an average of

63% of underlying demand*.

The all-time record for maximum renewable energy penetration in SA was set on 27 November 2021 at

135% of underlying demand.

SA minimum demand reached an all-time low on 21 November 2021



At the time, rooftop solar met **92%** of underlying demand.


*Underlying demand includes consumption met by behind-the-meter rooftop solar and battery storage.

Pre-incident conditions: 14/03/2021

- Planned outage put South Australia at credible risk of separation
- AEMO limits advice requires operational demand be maintained above a minimum threshold
- This is to manage two system security risks:
 - Risk A: Insufficient demand to maintain units online for system strength purposes
 - Risk B: Simultaneous loss of DPV (DPV contingency) - AEMO is seeing a trend of DPV disconnecting in response to transmission system trips.
- No issues shown in forecasts prior to 14 March and on the day

Key events

14 March 2021 South Australian actual operational demand and estimated DPV generation



— Operational demand - - - SA minimum demand threshold — Without intervention — Estimated DPV generation

Curtailment of DPV by SA Power Networks (SAPN)

- Direct SCADA control (~17 MW) – SAPN has direct SCADA control over DPV systems with capacity above ~200 kW
- Via Smarter Homes agents (~14 MW) – SAPN contact the relevant agent responsible for disconnecting/reconnecting DPV
- Enhanced Voltage Control (~40 MW) – SAPN increases the voltage on its network causing a subset of DPV system to disconnect from the system

Findings





Figure 2. Timeline of events

Recommendations



- DPV curtailment
- Minimum demand threshold
- Permission to Proceed
- Monitoring of real time demand
- Forecast uncertainty

Other Incidents

20 August 2020



11 April 2020





For more information visit

aemo.com.au

Operational Demand

- Operational demand in a region is demand that is met by local scheduled generating units, semi-scheduled generating units, non-scheduled intermittent generating units of aggregate capacity greater than or equal to 30 MW, and generation imports to the region.
- It excludes the demand met by non-scheduled non-intermittent generating units, non-scheduled intermittent generating units of aggregate capacity less than 30 MW, exempt generation, and demand of local scheduled loads.
- Because it excludes demand met by DPV, operational demand decreases as DPV generation increases.