



Capturing Net Load Uncertainty: RUC Uncertainty and Imbalance Reserve Requirements

Amber Motley

Director, Short Term Forecasting

Special thank you to Hong Zhou & Tobiah Steckel for work
in this area

June 2023

ESIG Meteorology and Markets Workshop – Denver, CO

Agenda

- CAISO Overview
- CAISO Net-Load Uncertainty Requirement Product Review
- Review metrics to analyze performance of probabilistic uncertainty forecasting
- Review of existing process
 - RUC Uncertainty Requirement Recommendation
 - Define Realized Uncertainty
- Review Transition to Imbalance Reserve Requirements
 - Extreme weather conditions considerations

California ISO

As a federally regulated nonprofit organization, the ISO manages the high-voltage electric grid.


52,061 MW record peak demand
(Sept. 6, 2022)

224.8 million megawatt-hours of electricity delivered
(2020)

75,747 MW power plant capacity
Source: California Energy Commission

1,119 power plants
Source: California Energy Commission

Since its launch in 2014, the Western EIM has enhanced grid reliability, generated millions of dollars in benefits for participants, and improved the integration of renewable energy resources.



*Avangrid office; generation-only BAA with distribution across multiple states.
Map boundaries are approximate and for illustrative purposes only.

Current Renewable Penetration Facts

Historical statistics and records *(as of 5/12/2023)*



Solar peak NEW!
14,812 MW

May 12, 2023 at 2:28 p.m.

Previous record:

14,774 MW, April 27, 2023



Wind peak
6,465 MW

May 28, 2022 at 5:39 p.m.

Previous record:

6,265 MW, March 4, 2022



Peak percentage of renewables compared to demand
103.5%

May 8, 2022 at 3:39 p.m.

Previous record:

99.87%, April 30, 2022



Peak net imports
11,894 MW

Sept. 21, 2019 at 6:53 p.m.



Peak demand
52,061 MW

Sept. 6, 2022 at 4:57 p.m.

Second highest:

50,270 MW, July 24, 2006



Steepest 3-hour average ramp
20,326 MW

Feb. 15, 2023 starting at 3:00 p.m.

Second highest:

19,699 MW, Jan. 23, 2023


¹ Based on 1-minute averages, and includes dynamic transfers. Values are subject to revision as data is refined.

² Indicates the highest amount of renewables serving peak electricity demand on any given day.

Currently Installed	Capacity
Number of Renewable Resources	507
MW Capacity Large Scale Renewables	23,094 MWs
MW Capacity Behind-the-Meter Solar	13,700 MWs

*Values are approximate as of April 2023

Net-Load Uncertainty Requirements



*** Day-Ahead Market Enhancements Analysis, slide 7

How do we assess the performance of probabilistic forecasts?

- Four criteria in measurements
 - Coverage: This is used to check the validity of a model, and is the coverage of observed uncertainty against the estimate requirement. The uncertainty requirement is targeted for 95%, which is achieved with 97.5% for upward and 2.5% for downward requirement.
 - Requirement: This is the average of the estimated requirement over a period of time.
 - Closeness: This is defined as the average distance between the observed uncertainty and the estimated requirement.
 - Exceeding: this is the average MW difference when the observed uncertainty is exceeding the estimated requirement.

Current Process: Definition of Observed (Realized) Uncertainty


Observed (realized) Uncertainty is:

$$*\text{Uncertainty}_{\text{RUC}} = \text{Max Net Load}_{\text{RTD Binding}} - \text{Net Load}_{\text{DA}}$$


Captures model bias, movement and uncertainty in one coherent metric

Additive Approach: Use of Uncertainty information into Load Conformance


CAISO Confidence Bands



Solar Confidence Bands



Wind Uncertainty Band




Additive Approach described

- **Load Uncertainty:**
 - guided by an upper confidence band.
 - Confidence band uses historical days to assess the maximum load forecast that could be exhibited under similar weather conditions.
- **Renewable Uncertainty:**
 - Guided by forecasting recommended value
 - Recommended value guided by historical vendor forecast performance under similar weather conditions and low probabilistic band provided by renewable providers
- **Solar net movement:**
 - Account for intra-hour ramp due to solar (sun-rise/sun-set)
- **Other (non-forecasted) additions by operators such as risk of fires**

Additive approach resulted in too high of RUC uncertainty requirements


RUC Requirement Utilized

7500 MW



Realized Uncertainty Observed

4500 MW



>9000 MW

Proposed Change: Utilize Imbalance Requirements (*similar* to DAME approved design)

- Simulation of performance over the last ~500 days, with highlighted periods (e.g., 2022 heat wave, Summer, >35,000 MW days)
- Trialed Methodologies
 - Mosaic methodology
 - 97.5% Net Load Histogram
 - 99% Net Load Histogram


Trialing Multiple Options: *Assessing different methodologies with different “configurations”*

The historical data utilized is critical to success of probabilistic forecast.

- **Sampling Scheme 1:** Rolling previous 90 days matching weekdays and 20 matching weekends.
- **Sampling Scheme 2:** A fixed 180 rolling days with varying number of weekdays and weekend (holidays included). The increased sample size will bolster the robustness of regression computations. This is the sampling scheme currently utilized for FRP.
- **Sampling Scheme 3:** In addition to the sampling scheme 1, us the forward historical data in last year anchored from a date similar to the current day with matching weekday/weekend. The scheme balances out backwards and forward data for any given day.

*Forms of Sampling Scheme 3 perform the best; next slides show 130 unique combinations trialed.

Trialing Multiple Options: *All results binned by time period or total load forecast*



Trialing Multiple Options: Broad takeaways

- When considering the most extreme (supply-constrained) days, a large departure in coverage between mosaic and histogram is evident
- When considering broader periods of time, mosaic has comparable coverage with a lower average requirement
- It is found that changing default configuration can assist in coverage during critical uncertainty days

Next Steps

- As the ISO continues to evolve the assessment of uncertainty and how it could guide RUC adjustments, the ISO is working to incorporate Imbalance Reserve Requirement Design during all non **Weather Extreme** days.
- Upon results work towards process too allow **change to the percentile** utilized to protect coverage **during weather extremes**.
 - This is similar to the process ran for regulation requirements.
- Continue to further assess non-heat driven events coverage

APPENDIX

Imbalance Reserves vs. Real-Time Flexible Ramping Product

Imbalance Reserves

- Hourly Product
- 15-minute dispatchable (30-minutes of ramp)
- Biddable
- Covers granularity difference and uncertainty between DAM and FMM
- All awards are co-optimized and settled simultaneously





Figure 2: Hourly trend of Day-Ahead Imbalance Reserve. Copyright © 2023

RT Flexible Ramping Product

- 15-minute product
- 5-minute dispatchable
- Not biddable
- Cover uncertainty from FMM to RTD
- Awards are calculated in successive runs and are only settled from the binding to the first advisory interval
- Demand Curve for uncertainty



Proposed methodology (green line) tracks more closely the solar production conditions, while current methodology (red line) is constant at any level of solar production




California ISO


Forecasting and Monitoring Extreme Weather Conditions

Forecasting Awareness and Transparency


- **Forecasting alerts** generated from **team of trained meteorologists** to identify extreme weather conditions up to 365 hours ahead of the event.
 - Weather, load, renewable, and fire forecasting/alerts
 - Forecasting and alerts cover CAISO area, WEIM areas, and the West at large




Assessing Weather Uncertainty Impact



Fire Forecasting Tools and Alerts



[Wildfire Forecasts \(pyrecastrg.org\)](https://www.pyrecastrg.org)



[High-Resolution Rapid Refresh \(HRRR\) \(noaa.gov\)](https://www.noaa.gov)

Fire Weather Forecast:



Monitoring SoCal Interior during extended period of hot/dry conditions.

Value	Fire Risk
1	Normal
2	Elevated
3	Extreme

Fire Risk Matrix											
	Region	Thu 9-1	Fri 9-2	Sat 9-3	Sun 9-4	Mon 9-5	Tue 9-6	Wed 9-7	Thu 9-8	Fri 9-9	Region
PG&E	Bay	1	1	1	1	1	1	1	1	1	Bay
	Non-Bay	1	1	1	1	1	1	1	1	1	Non-Bay
SCE	Coast	1	1	1	1	1	1	1	1	1	Coast
	Inland	2	2	2	2	2	2	2	1	1	Inland
SDG&E	Coast	1	1	1	1	1	1	1	1	1	Coast
	Inland	2	2	2	2	2	2	2	1	1	Inland

BYRON
 CONTRA COSTA COUNTY, CA
 .43 miles from Substation1-Substation2
 .58 miles from Substation4-Substation5
 Last Update: 5/19/2022, 2:44 AM
 First Reported: 5/19/2022, 2:44 AM

ARMSTRONG
 CONTRA COSTA COUNTY, CA
 .43 miles from Substation1-Substation2
 .58 miles from Substation4-Substation5
 Last Update: 5/18/2022, 5:56 PM
 First Reported: 5/18/2022, 5:56 PM



(1 of 3) TELEGRAPH INCIDENT

Type: WF - Wildfire
 Area Acres Burned: 87,119
 Percent Contained: 76%
 Discovered: 6/4/2021, 1:37 PM
 FlightRadar24: <https://www.flightradar24.com>
 Twitter: #TelegraphFIRE
 Current as of 6/12/2021, 6:31 PM

Zoom to

firenotification@caiso.com Bohlen, Justin; + 5- 3/12/2022

FIRE ALERT

----FIRE ALERT----

BYRON FIRE:
 Contra Costa County, CA
 -121.577, 37.812
 -0.43 miles from Substation1-Substation2 500kv line
 -0.58 miles from Substation4-Substation5 line

