


Potential Impacts of Climate Change on Bulk Power System Planning and Operation

Bri-Mathias Hodge, Ph.D.



Chief Scientist and Distinguished Member Research Staff, NREL
Associate Professor – Electrical, Computer & Energy Engineering, CU Boulder
Associate Director and Fellow – Renewable and Sustainable Energy Institute

The Elephant in the Room



Monthly global mean temperature 1851 to 2020 (compared to 1850-1900 averages)




Climate-Driven Changes to Solar PV Power




Climate-Driven Changes to Wind Power





Climate Impacts - Planning



Climate Impacts - Operations



Load Changes with Temperature Changes - TVA



Duke Energy Carbon-Free Resource Integration Study

NREL
Transforming ENERGY

Search NREL.gov SEARCH

Grid Modernization

Research Publications Data & Tools Facilities Work with Us

Grid Modernization > Carbon-Free Resource Integration Study

Carbon-Free Resource Integration Study

In the Carbon-Free Resource Integration Study, NREL is investigating the impacts of varying scenarios of carbon-free generation on electric power systems in the Carolinas.

Duke Energy is working to cut CO₂ emissions by at least half (from 2005 levels) by 2030 and attain net-zero CO₂ emissions by midcentury. As it integrates increasing amounts of renewable and distributed energy resources into its electric power systems, Duke Energy commissioned this study to understand the integration, reliability, and operational challenges and opportunities ahead.

Phase 1 Study

For Phase 1 of the study, NREL performed an analysis of the Carolinas' carbon-free resource integration capability. Phase 1 included the evaluation of 12 scenarios to examine the impact of increasing levels of solar photovoltaic (PV) generation on the total percentage of carbon-free generation. The study evaluated wind, storage, and PV penetration scenarios reaching as high as 80% of annual carbon-free energy. Although Phase 1 does not make specific recommendations, it does provide high-level information about potential future resource mixes.

Global Horizontal Irradiance
North Carolina and South Carolina

kWh/day
4.90 - 5.01
4.80 - 4.89
4.70 - 4.79
4.60 - 4.69
4.50 - 4.59
4.40 - 4.49
4.30 - 4.39
4.19 - 4.29

Integrated Devices & Systems

Sensing, Measurement, & Forecasting

Power Systems Operations & Controls

Power Systems Design & Studies

Distribution Integration

Transmission Integration

Transient & Dynamic Stability Analysis


Power Market Design

Integrated Energy System Simulation

SMART-DS

Security & Resilience


Institutional Support



Overview of Phase II analysis

Capacity Expansion

Installed capacity in the Carolinas



Note: The coal retirement schedule for these results was specified prior to recent updates. A sensitivity exploring runs with additional coal retirements was tested in production cost modeling.

2030 timeframe

- Policy results in increase solar and storage
- Base and policy cases are similar – highlights that a substantial amount of solar and storage are economic under default assumptions


2050 timeframe

- Additional solar, along with longer-duration storage resources and offshore wind
- Deployment of “RE-CTs” as a zero-carbon peaking resource (low-capacity factor)

Capacity Expansion

Curve illustrates cumulative avoided emissions vs. policy costs

- 2030-2035: steepness of the line reflects the fact that avoided emissions are relatively cheap
- 2035-2048: line flattens out; cost to mitigate are increasing
- 2048-2050: moving to zero carbon results in larger costs
 - Cost of removing the final 30-45 MMT of CO₂ are almost about as high as the cost of removing the first 186 MMT
 - Reflecting the increase in average cost of mitigation from ~\$7 per metric ton in 2030 to ~\$27 per ton in 2050



Cumulative CO₂ abatement cost through 2030 and 2050 (\$ per metric ton). Values in parentheses indicate range across ReEDS sensitivities.

2030	2050
7 (6-20)	27 (9-34)

Production cost modeling cases


Two categories of production cost modeling cases: nodal and zonal

Nodal: Full transmission representation of Duke Energy's system; each case built by adding ReEDS builds to an existing network model

- 2024 buildout + 2012 weather (baseline)
- 2030 buildout + 2012 weather (policy case w/ 70% CO₂ reduction in NC)
- 2030 buildout modified + 2012 weather (includes accelerated coal retirements)
- 2036 buildout + 2018 weather (tests extended cold period; also includes coal retirements and offshore wind)

Zonal: Transmission matches ReEDS aggregation, with only the interfaces between BAs modeled

- 2024 buildout + 2012 weather (baseline)
- 2050 buildout + 2012 weather (policy case with zero-emissions)




Nodal system


	El	Duke
Buses	78,463	2,944
Lines	71,328	3,176
Transformers	27,901	890

2030 policy case, nodal model

Placement for onshore wind and utility-scale solar




Nodal results – Summer Peak Dispatch



- Coal replaced with natural gas, solar, and in the 2036 buildout wind
 - Gas CTs used heavily in the evening hours after coal is retired
- Storage charges during the morning/daylight hours when solar is prevalent; discharges in the evening when solar ramps down


Nodal results – Winter Peak Dispatch

Duke



- 2012 weather year had a relatively brief winter peak which can be met primarily through a combination of nuclear, gas, solar, wind, and storage
- 2018 weather year had sustained low solar output + high load due to an extended cold snap
 - Demand peaks around 37 GW (annual peak)
 - Heavy use of Gas CC and CTs to meet demand
 - Storage charges during the day, discharges overnight
 - Offshore wind and imports help to meet remaining energy needs

RE-CT fuel consumption



- RE-CTs in the “no fossil” case are used to meet peaking requirements
 - Low annual capacity factor
 - High use when deployed
- Plot illustrates the quantity of renewably-sourced fuel that needs to be provided to sustain output in those periods
 - Could be H₂, biofuel, or some other peaking resource
 - Implies sufficient pipeline infrastructure or storage capacity to supply ~3 million mmBTU at a time, and that renewable fuel is available
- Other technologies such as seasonal storage could also fill this role

Acknowledgements

- Dr. Brian Sergi – NREL
- Dr. Carlo Brancucci – NREL (Encoord)
- Prof. Michael Craig – NREL (Michigan)
- Prof. Paulina Jaramillo – CMU
- Ignacio Losada Carreno – NREL (Cornell)
- Dr. Omar Guerra – NREL
- Dr. Sue Ellen Haupt – NCAR
- Dr. Caroline Draxl - NREL





Thank you!

