


# Present and Future Operation of the Ireland Power System

Damian Flynn

University College Dublin




# All-Island Power System



- Peak demand - 6.89 GW
- All-island, dual currency single electricity market (SEM)
- Gas / coal / peat / hydro / ...
- 2 x 500 MW HVDC
- Wind capacity – <sup>(4.47)</sup> 5.58 GW
- Solar PV capacity – 336 MW
- Annual wind energy – 36%
- Maximum % wind – 147 / 96%
- SNSP stability limit – <sup>(71.8)</sup> 70%

# Operational Rules All-Island



- Major load centres
- 3 units required in N. Ireland
- 5 units required in Ireland

Regional must-run plant

I-NI inter-area flow  $\leq 400$  MW


SNSP  $\leq 70\%$  (75%)

RoCoF  $\leq 0.5$  Hz/s (1.0 Hz/s)


Inertia  $\geq 23,000$  MWs

# System Non-Synchronous Penetration

February 2021




# Wind Dispatch Down 2020





# Solar PV Dispatch Down 2020

Northern Ireland



# Wind Forecasting

- Primary and secondary wind vendors appointed



# System Services Categories


<b>Reserve</b>	Primary Operating Reserve	Secondary Operating Reserve	Tertiary Operating Reserve 1
<b>Ramping</b>	Tertiary Operating Reserve 2	Replacement Reserve (De-synchronised + Synchronised)	
<b>Reactive Power</b>	Steady-State Reactive Power		



# System Services Categories October 2018

<b>Reserve</b>	Primary Operating Reserve	Secondary Operating Reserve	Tertiary Operating Reserve 1
<b>Ramping</b>	Tertiary Operating Reserve 2	Replacement Reserve (De-synchronised + Synchronised)	
<b>Reactive Power</b>	Steady-State Reactive Power	Ramp Margin (1 hr + 3 hr + 8 hr)	
<b>Inertia</b>	Synchronous Inertial Response		
<b>Fast-acting</b>	Fast Frequency Response	Fast Post-Fault Active Power Recovery*	Dynamic Reactive Reserve*


# Payment Arrangements



- Performance scalar
- ~ Reliability of service
  - ~ Speed of response
  - ~ Dynamic response (non-stepped)
  - ~ Enhanced delivery (multiple products)
  - ~ Scarcity of supply (temporal and locational)
  - ~ Availability forecast accuracy ?


# Climate Action Plan 2019

- 70% renewables target by 2030
- <8.2 GW onshore & 3.5+ GW offshore wind capacity
- <1.5 GW grid-scale solar capacity
- 70 GW ocean energy potential
- Carbon tax of €80+ by 2030
- Develop district heating roadmap
- 950,000 EVs on the road
- 600,000 heat pumps at residential level
- *Support for net zero emissions target by 2050*
- **Climate Bill – 51% emissions reduction by 2030**




# Demand vs. Generation 2020

## Demand




## Generation




# Demand vs. Generation 2030


Demand



Generation



# Ireland + N. Ireland 2030




Facilitation of Renewables Studies defined SNSP stability limit of 75%  
**75% (trial) stability limit in 2021**  
**95% SNSP target for 2030**



# System Scarcities 2030


	No Scarcity	Evolving Characteristic	Concern	Scarcity
	Continental Europe	Ireland & Northern Ireland	Nordic System	
RoCoF (dimensioning incident)	Localised concern	Inertia scarcity	Evolving characteristic	
RoCoF (system split)	Global concern	N/A	Not analysed	
Frequency containment (dimensioning incident)	Evolving characteristic	Evolving characteristic	Evolving characteristic	
Frequency containment (system split)	Global concern	N/A	Not analysed	
Steady State Voltage Regulation	SS reactive power scarcity	SS reactive power scarcity		
Fault Level	No scarcity	Dynamic reactive injection scarcity		
Dynamic Voltage Regulation	No scarcity	Dynamic reactive injection scarcity		
Critical Clearing Times	Evolving characteristic	Evolving characteristic		
Rotor Angle Margin	Not analysed	Localised concern		
Oscillation Damping	Damping scarcity	Damping scarcity		
System Congestion	Global concern	Transmission capacity scarcity		
System Restoration	Not analysed	Evolving characteristic		

# Loss of Largest Infeed/Outfeed






# Loss of Largest Infeed




# N-1 Low Voltage Scenarios

Shortage of steady-state reactive power capability



# N-1 Transmission Network Overloading



Desirability for congestion related system service?





# Bolted 3-Phase Line Faults

Requirement for dynamic reactive response capability

**Fault  
Location  
A**





**Fault  
Location  
B**







# Voltage Dip-Induced Frequency Dips



# Post-Fault Active Power Recovery




# Post-Fault Active Power Recovery





# 100% SNSP Scenario



- Major load centres
- ☀ PV generation
- 🌪 Wind generation


System grid-forming ratio

$$SGFR_{100} = \frac{GF_{\text{online}}}{GF_{\text{online}} + gf_{\text{online}}}$$

System non-synchronous penetration


$$SNSP = \frac{P_W + P_{HVDC(\text{imp})}}{P_L + P_{HVDC(\text{exp})}}$$

# Grid-Forming Control Strategies





Droop control

$$\omega = \omega_{ref} + k(P - P_{ref})$$







Synchronous machine matching



Virtual oscillator control (VOC)

# 3-Phase Fault at Inchicore (near Dublin)


Mix of droop + dVOC grid-forming controls



# Wind Power Distribution 2081-2100





Winter

Summer







# Extended Low-Power Events 2081-2100

Onshore



Offshore



# ... Some Open Questions

- How best to achieve cost effective operation while maintaining system stability with increasing RES?
- Can we avoid building new lines while facilitating demand growth and new generation?
- Growth and nature of *self-consumption*?
- How to incentivise plant portfolios which maintain system adequacy?
- Need for and desirability of seasonal storage?
- *Should CO<sub>2</sub> reduction objectives outweigh economic / least cost motivations?*

# Present and Future Operation of the Ireland Power System


Damian Flynn

([damian.flynn@ucd.ie](mailto:damian.flynn@ucd.ie))

University College Dublin




# Facilitation of Renewables Studies






# Wind Dispatch Down 2020



# Load vs. Generation Distribution



Demand

Conventional  
Generation


Renewable  
Generation



# Synchronous Inertial Response



Synchronous Inertial Response Factor




SIRF = Rotational Energy / Min Stable Generation (s)

Payment  $\propto$  (Rotational Energy x SIRF)



# Fast Frequency Response



# Dynamic Reactive Response

